C/37

# GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
# HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
# NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2025/ 826 Dated: 20 /11/2025

To,

Smt. Asha Rani (Principal),
M.C.D. Pratibha Boys / Girls School,
Raj Nagar, Palam Colony,
New Delhi – 110077.

Subject: Renewal of Fire Safety Certificate in r/o M.C.D Pratibha Boys / Girls School Located at Raj Nagar, Palam Colony, New Delhi – 110077 (School ID-1757216)

Sir,

Please refer to your letter No- form J dated 18/09/2025 on the subject mentioned above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 04/11/2025 in presence of Smt. Sangeeta (Incharge) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Hose reel hoses found damaged.
2. Terrace pump found nonfunctional.
3. Over head water tank of 10,000 ltr capacity found damaged /removed.
4. Exit Signage found removed.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

19/11/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to; - Directorate of Education Old Secretariat Delhi – 110054