C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/EH/2025/SZ/ 446 Dated: 24 /11 /2025

To,

Sh. Rajeev Goel,
M/s McDonald's Family Restaurant (M/s Connaught Plaza Restaurant Pvt. Ltd.),
Ground floor, Shop no. 02 & 03, Eros Cinema Building,
Jangpura Extension,
New Delhi-110014

Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s McDonald's Family Restaurant (M/s Connaught Plaza Restaurant Pvt. Ltd.), Ground floor, Shop no. 02 & 03, Eros Cinema Building, Jangpura Extension, New Delhi-110014.

Sir,

This has a reference to your MCD online application ID No. 2025110714653 dated 08/11/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 14/11/2025 in presence of Manager and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/Industrial/SZ/2024/371 dated 27/06/2024 (copy enclosed) have not been complied yet.

In view of above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Encl. As above

24/11/25
(A. K. MALIK)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -
The Commissioner, MCD, Civic Centre, New Delhi
MCD online Portal ID-2025110714653

O/C

C-68 C/61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2024/ 371 Dated: 27/06/2024

To,

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **M/s McDonald's Family Restaurant (M/s Connaught Plaza Restaurant Pvt. Ltd.)** located at **Ground floor, Shop no. 2 & 3, Eros Cinema Building, Jangpura Extension, New Delhi-14.**

Sir,

With reference to the MHA online application no. 2024060508832 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 20.06.2024 in the presence of Mr. Rohit (Manager) and it was observed that the restaurant is running on ground floor of the building which is comprised of Two tier Basement + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. The alternate exit width of minimum 1.45 meters shall be provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

20/6/24