C-74

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/ 03 Dated:-05/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of FSC in r/o McDonalds Family Restaurant (A unit of Connaught Plaza Restaurants Pvt. Ltd), 5/76, West Ajmal Khan, Padam Singh Marg, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2025121715826 dated 18/12/2025, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officer concerned of this department on **26/12/2025** in the presence of **Ms. Rachna (Restaurant Manager)** and following shortcomings were observed: -

1. Alternate staircase was found removed.
2. Width of main exit door is 1.10 mtr. against the requirement of 1.50 mtr.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

2/1/26

(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

O/C BR

Copy to: -

1. The Manager, McDonalds Family Restaurant (A unit of Connaught Plaza Restaurants Pvt. Ltd), 5/76, West Ajmal Khan, Padam Singh Marg, Karol Bagh, New Delhi - 110005.