C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2026/SZ/ 67 Dated: 21 / 01 /2026

To

The Principal,
M.C. Primary School,
New Roshanpura–II,
Najafgarh, New Delhi–110043

Sub: **Renewal of Fire Safety Certificate in r/o M.C. Primary School located at New Roshanpura–II, Najafgarh, New Delhi–110043 (School ID: 1757103)**

Sir,

Please refer to e-mail dated 18/09/2025 received from Id. <roshanpura.new2@gmail.com> along with attachment, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 09/01/2026 in the presence of Ms. Babita (Safai Karamchari). During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose provided found non-functional.
2. Terrace level fire pump found non-functional.
3. Over-head water storage tank capacity 10,000 liters found empty.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

20/1/26

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, MCD, Civic Centre, Minto Road, New Delhi–110002.