d/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2026/ 82 DATED: 23/01/2026

To,

The, Principal,
M.D.H International School(An institute of Mahashya Chuni Lal Charitable Trust)
Plot No 3, Pocket 2, Sector 6, Dwarka,
New Delhi 110075.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o M.D.H International School(An institute of Mahashya Chuni Lal Charitable Trust) Located at Plot No 3, Pocket – 2, Sector – 6, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter no. DW6/0110/2022-occ dated 02/01/2026on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 14/01/2026 in presence of Sh. Madhuban Bhai Patel (AE/DDA)Sh. Surya Pratap (JE/DDA) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The width of entry gate found less than 6mtr.
2. Six meter wide internal road around the building found encroached/blocked
3. Width of Class room doors are less than 1.2 mtr required width at 4th floor
4. Fire Check Doors found not provided.
5. Hose reel hose & hydrants found nonfunctional.
6. Manually operated fire alarm system (MOEFA) found nonfunctional.
7. Public address system found nonfunctional.
8. Terrace tank of 25000ltrs capacity not provided.
9. Terrace pump of capacity 900 lpm found nonfunctional.
10. Exit signage found not provided at some places.
11. PA System Panel, Battery backup & Building Floor Plans in fire control room found not provided.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter

Yours faithfully

23/1/26

(A.K. MALIK)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service
9044

Copy to:-

1. The Jt.Director (L&I)Bldg. DDA, Vikas Sadan New Delhi.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054