GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 168 Dated 29/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Mehak Restaurant located at F – 39, Ground floor, East of Kailash, New Delhi – 110065.

Sir,

This has a reference to MHA application No. 2026012800940 dated 28/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/02/2026 in the presence of Mr. Rupesh (Manager) and observed that building comprised of Basement, Ground plus two upper floors, Restaurant running on Ground floor only.

Following shortcomings were observed during time of inspection:

1. Smoke Management System but not functional.
2. First Aid Hose Reel provided but not functional.
3. MOEFA provided but not functional.
4. PA system provided but not functional.
5. Internal hydrant provided but not functional.
6. Terrace pump provided but not functional.
7. Overhead tank found removed.
8. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

M. K Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service