1/25

# GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
## HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/SZ/2025/ 309 Dated:- 17/02/2026

To

Sh. Rahul Nangia,
Mil office at 3nd floor, Tower J-101,
World Trade Centre Nauroji Nagar,
New Delhi.

Sub: Request for No Objection Certificate in r/o Mil office at 3nd floor, Tower J-101, World Trade Centre Nauroji Nagar, New Delhi.

Sir,

This has a reference to email dated 07.01.2026, on the subject cited above. In this regard, this is to inform you that the site was visited by the officer concerned of this department along with Sh. Rahul Nangia on dated 02.02.2026, to check and verify the compliance of the condition of Fire Safety Certificate in r/o lay out of interior finishing /fit out of furniture and functionality /extension of existing firefighting arrangements. During the visit the following shortcomings were observed.

1. Hydrant line found dry /without water and hydrant coupling & nozzle from hose reel was also found missing.
2. Exit signages are also not provided at conspicuous location.

In view of above, the application for issuances of no objection certificate /FSC for occupy the space in said floor is rejected. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

13/2/26

**A.K. Malik**
**Dy. Chief Fire Officer**
**Delhi Fire Service**

**Copy to :**

1. The Chief General Manager, NBCC of Redevelopment of Nauroji Nagar, New Delhi-29.