GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2026/EZ/714 Dated: 23/07/2026

To

Ms. Meenu Arora (Manager),
Modern Era Public School,
B–328, Ashok Nagar, Mandoli Road,
Shahdara, Delhi–110092,

Sub: **Renewal of Fire Safety Certificate in r/o Modern Era Public School, B–328, Ashok Nagar, Mandoli Road, Shahdara, Delhi–110092.**

Sir,

This has reference to the online portal application No. **52026012900692**, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 10/07/2026 in your presence to verify the compliance of shortcomings earlier communicated by this department vide letter No. F6/DFS/MS/2019/1636 dated 02/04/2019. During course of inspection, it was observed that the shortcomings have not yet been rectified.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage and rejected. You are requested to rectify the shortcomings under intimation to this department for further action in the matter. The occupancy of the building till the compliance of the shortcomings shall be at the risk and responsibility of the school management.

Yours faithfully,

23/7/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, Govt. of NCTD, B-Block, Yamuna Vihar, Delhi–110053

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F-6/DFS/ms/2019/1636 Dated 2/4/19

To,

The Manager,
M/s Modern Era Public School,
B-328, Ashok Nagar Mandoli,
Delhi 110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Modern Era Public School at B-328, Ashok Nagar Mandoli, Delhi 110094.

Sir,

This is in reference to your letter No. MEPS/172, Dated 07/02/19 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mrs. Meenu Aroda, Manager. During the course of inspection the following points / shortcomings were noticed in the school building comprised of ground plus two upper floors.

1. The width of staircase shall be 1.50 meter or an additional staircase of 0.75 meter shall be provided.
2. Only 02 fire extinguishers provided in place of 06 fire extinguishers as required.
3. First-Aid hose reels not provided.
4. A fire pump having 225 LPM output at 40 meters head not provided at terrace.
5. Over Head water storage tank 2,500 liters capacity exclusively for fire fighting not provided at terrace.
6. Exit Signage not provided.

In view of above, the school building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy:-

The Director of Education, EDMC,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area,
Delhi-110092