GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/School/NDZ/2026/ 528 Dated: 29/05/2026

To

The Principal,
Mother Mary's School,
Sahkarita Marg, Mayur Vihar Ph-1,
Delhi-110091.

Sub:- Regarding renewal of Fire Safety Certificate in respect of Mother Mary's School located at Sahkarita Marg, Mayur Vihar Ph-1 Delhi-110091.

Sir,

With reference to the letter bearing outdoor diary no. 656 dated 22/04/2026 on the subject cited above, it is informed that the school building was inspected by officer concerned of this department on 05/05/2026 in the presence of Sh. Satish Bhat (Estate Manager) and following shortcoming was observed: -

1. Fire Check Door (FCD's) not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

27/5/26

(Dr. S.K. Tomar)
Chief Fire Officer (NDZ)
Delhi Fire Service

Copy to:-.

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.