C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ EN/ 899 Dated: - 28/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o MS Echoes Hospitality LLP, located at Shop No. 7, Ground Floor, Block-D, Prashant Vihar, Rithala, Rohini, Delhi-110085.

Sir,

This has reference to online application no. 2026082010581 dated 21/08/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 07/09/2026 in the presence of Sh. Himanshu (Operational Manager). During inspection, it was observed that the above said restaurant is running at ground floor only in a building comprised of basement + ground + 03 upper floor + 01 room & 01 toilet at 4th floor. After inspection, the following shortcoming were observed: -

1. Only one exit door of width 2.0 m is provided against the requirement of 02 nos. exit doors, each having minimum width of 1.50 m.
2. Fire check door is not provided at kitchen.
3. Smoke Management System is not provided.
4. First-Aid Hose Reel is provided but found non-functional.
5. Fire pump of 450 LPM is provided but found non-functional.
6. Overhead water storage tank of 10,000 ltrs capacity is provided against the requirement of 20,000 ltrs.
7. Standby power supply is not provided.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

28/9/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, MS Echoes Hospitality LLP, located at Shop No. 7, Ground Floor, Block-D, Prashant Vihar, Rithala, Rohini, Delhi-110085.