C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2025/WZ/853
Dated: 27/11/2025

To,

The Principal,
Nand Bharti Public School,
44, Friends Enclave, Sector 5,
Nangloi, Delhi-110086.

Sub:- Renewal of Fire Safety Certificate in respect of Nand Bharti Public School located at 44, Friends Enclave, Sector-5, Nangloi, Delhi- 110086.

Sir,

This has reference to your letter no. Nil dated 04/11/2025 received through outdoor diary no. 7900 dated 06/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.11.2025 to see the compliance of the requisite fire safety measures. Smt. Varsha Arora was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of 02 Blocks (Ground floor & Ground plus First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reel nozzle found missing.
2. Terrace level pump & over head water storage tank could not be checked because terrace found locked.
3. Exit signages found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

27/11/25

(S.K. Dua)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.