GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2026/WZ/332 Dated: 03/08/2026

To,

Sh. Vivek Kumar, Dy. Director (Admn. & Plg)
National Institute of Social Defence,
Plot No. G-2, Sector- 10, Dwarka, New Delhi.

Sub: - Regarding renewal of FSC in r/o National Institute of Social Defence at Plot No. G-2, Sector- 10, Dwarka, New Delhi.

Sir,

This has reference to letter No. Nil, dated 17.06.2026, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on dated 16.07.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Hatoz, was present and it was observed that the building comprised of basement, ground plus 06 upper floors, and following shortcomings were observed: -

1. Hose Reels provided in each block but found not functional.
2. Automatic fire detection and alarming system provided but found not functional.
3. MOEFA and PA system provided but found not functional.
4. Automatic Sprinkler system provided but found not functional.
5. Internal hydrant and Yard hydrant provided but found not functional.
6. Fire pumps provided as per requirements but found not functional.
7. Exit Sign's found removed at few places.

In view of the above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter. The building remains unsafe from fire safety point of view and it shall be at the risk & liability of the management committee until the compliance.

Yours faithfully

29/07/26

(S.K. Dua)
Chief Fire Officer
West Zone

Copy to: -

1. The Dy. Director (L&I), Building Section, Delhi Development Authority, Vikas Sadan, INA, New Delhi- 110023.