C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/WZ/2025/College/144 Dated: - 04/12/2025

To,

Sh. Dhirender Khatri,
Administrative Officer,
National Institute of Homeopathy,
Ministry of Ayush, Govt. of India,
Sector-A8, Chaudhary Ramdev Chowk, Narela, Delhi-110040 .

Subject: Regarding renewal of Fire Safety Certificate in respect of National Institute of Homeopathy, Delhi, located at Sector-A8, Chaudhary Ramdev Chowk, Narela, Delhi-110040.

Sir,

This has reference to your letter no. P-16023(12)/2025-US C1/1/238 dated 17/10/2025 on the subject cited above. In this connection, it is to inform you that above said building was inspected by the officers concerned of this department on 15/11/2025 in the presence of Sh. Dheeraj Saimil (J.E., Civil) & Ms. Shivi Singh (J.E., Electrical). During inspection, it has been observed that the said building is comprised of 02 Blocks, Hospital Block (B+G+5), Academic Block (B+G+4). However, the following shortcomings have been observed as under:-

1. Smoke Management system found non-functional.
2. Automatic fire detector system found non-functional.
3. MOEFA found non-functional.
4. Public Address System found non-functional.
5. Pressurization of Staircases/Lift well/Lift lobbies were provided but found non-functional.
6. Fire pump were provided but not on auto mode.
7. Firefighting system/detection system are not integrated.
8. No trained fire staff was available during the time of inspection.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,

02/12/25

S.K. Dua
Dy. Chief Fire Officer (WZ)

01/12/25