e 51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/ECN/2026/116 Dated: -28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **Navyug School** located at **Mandir Marg, New Delhi** comprises of **Basement, Ground and 02 Upper Floors** was earlier granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2023/School/251 dated 11.04.2023. Now, the premises was inspected by the officer concerned of this department on **13/07/2026** in the presence of **Sh. Virender Kumar Sharma, Leading Fireman (NDMC)** and found that the said school premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "**Educational Building**" with effect from 28/07/2026 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ..28/07/2026..at New Delhi by.

28/7/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OC88

Copy to: -

1. The Principal, Navyug School, Mandir Marg, New Delhi.
2. The Directorate of Education, Govt. of NCT of Delhi, Room No. 12, Old Secretariat, Civil Lines, Delhi – 110054.
3. The Chairman, NDMC, Palika Kendra, Netaji Nagar, New Delhi – 110001.

Condition for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	Navyug School, Mandir Marg, New Delhi.		
2.	Type of occupancy	Educational Group – B		
3.	Building is Comprised of	Basement, Ground and 02 Upper Floors		
4.	Type of case	**Renewal**		
5.	Details of previous FSC No.	F6/DFS/MS/2023/School/251 dt. 11.04.2023		
6.	Fire safety directives No.-	N/A		
7.	Date of inspection: -	13/07/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(ND)		
9.	Name & designation of officer From the building side: -	Sh. Virender Kumar Sharma, Leading Fireman (NDMC)		
10.	Year of construction: -	2006		
11.	Applicant's letter No: -	DFS Online Portal ID: - 52026061003577 dated 22.06.2026		
S. No.	**Minimum Standards on fire Prevention and fire safety U/R 33**	**Requirement as per Circular of Director of Education - 2011**	**Provided at site**	**Remarks MR/NMR**
1.	**Access to Building**			
	• Road width	Accessible	12.00 mtr.	MR*
	• Gate width	5.00 mtr.	5.00 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper floors	03 nos.	03 nos.	MR
	• Basements	03 nos.	03 nos.	MR
	b. Width of staircase			
	• Upper floors	1.50 mtr.	1.60, 1.50 & 1.48 mtr.	MR
	• Basements	1.50 mtr.	1.60, 1.50 & 1.48 mtr.	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	03 nos.	03 nos.	MR
	e. Width of corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	Required	Provided Exhaust Fan	MR
	• Upper floors	Required	Provided Natural	MR
5.	**Fire Extinguishers**			
	• Total numbers	24 nos.	26 nos.	MR
	• Types	ABC & CO_2	ABC & CO_2	MR
	• ISI marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reel**			
	• Total number of each floor	03 nos.	03 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	**Automatic Fire Detection & Alarming System.**			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A

	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	03 nos.	03 nos.	MR
	• Hose box per floor	03 nos.	03 nos.	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	**Pumping Arrangement**			
	Ground level			
	• Discharge of main pump	1620 LPM	1620 LPM	MR
	• Head of main pump	30 mtr.	30 mtr.	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	30 mtr	30 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	**Captive Water Storage for Fire Fighting**			
	• Underground tank capacity	50,000 Ltrs	50,000 Ltrs	MR
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	**Stand by Power Supply**	Required	Provided	MR
18.	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A

20.	**Special Fire Protection System for Protection of special Risk, if any: ABC, CO_2**	MR

*PNF - Provided but Non-Functional, *MR - Meeting Requirement, *NMR - Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/2023/School/251 dated 11.04.2023, under Rule 35(6) of the Delhi Fire Service Rules 2010.

Accordingly, **DFA** is prepared and put up for perusal and signature please.

Bhupender Prakash
21/7/2026

Bhupender Prakash
ADO (ND)

DO (NDD/ODD) Sanctioned 21/7/2026

CFO (ECN) 22/7/26

CFO As noted.

Principal Director 24/7/26

CFO (ECN) 24/7/26

ADO (ND)

As approved F.T. letter is put up for Signature please.

Bhupender Prakash
27/7/2026

CFO (ECN) 28/7/26

MS