C-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH/NDZ/2026/267 **Dated:** 30/03/2026

To,

Mr. Danish
M/s Nazeer Foods A unit of Sudha Rao Danish and Co.
Shop No 215, Gali No. 03, Monga Nagar, Karawal Nagar,
Delhi-110094.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Nazeer Foods A unit of Sudha Rao Danish and Co. located at Shop No 215, Gali No. 03, Monga Nagar, Karawal Nagar, Delhi-110094.

Sir,

This has reference to MCD online application ID No. 2026022502030 dated 25/02/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 16/03/2026 in presence of Mr. Danish, Owner. The building is comprised of ground plus two upper floors but restaurant is running on ground floor only. The following shortcomings were observed during the time of inspection.

1. Second door passing through the kitchen
2. Fire check door not provided in the kitchen.
3. Smoke management system not provided in the restaurant.
4. First aid hose reel provided but not functional.
5. Down comer is provided but not functional.
6. Terrace pump 450 lpm head 40 meter provided but not functional.
7. Overhead tank capacity 5,000 liters provided against the requirement of 20,000 liters.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

27/3/26

(Dr. S. K TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above

MCD ID No. **2026022502030**