GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2026/ 801 **Dated:** 25/08/2026

To,

Sh. Abhishek Pal,
Nazeer Hospitality Pvt. Ltd.,
D- 590,1st & 2nd Floor, I.P Extension,
West Vinod Nagar
Delhi-110092

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Nazeer Hospitality Pvt. Ltd located at D- 590,1st & 2nd Floor, I.P Extension, West Vinod Nagar Delhi-110092

Sir,

This has a reference to MCD online application ID No. 2026070809622 dated 18/07/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 10/08/2026 in presence of Sh. Shrikant, Manager. The building is comprised of Ground plus three upper floors but guest house is running first and second floor only and third floor sealed by the MCD. The following shortcomings were observed during the time of inspection.

1. One staircase width 01 meter provided against the requirement of two staircase of width 1.50 meter each.
2. Fire check doors are not provided.
3. Corbon mono oxide detector not provided.
4. Fire Extinguishers not provided
5. First-aid-Hose Reel at each floor not provided
6. MOEFA not provided.
7. Terrace pump capacity 450 lpm head 40 meter is not provided.
8. Overhead Tank capacity 10,000 liters is not provided.
9. Exit signages not provided.

In view of above, **the application for issuance of Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangement s shall be at the risk and liability of the owner/occupier, The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

24/8/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFCIER

Copy to: -

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002
   MCD ID No. 2026070809622