**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/SZ/2026/ 123 Dated 20/01/2026

To,

The Manager,
NBT Banquet hall ( A Unit of TG hotels LLP)
Khasra No. 646-653,
Village Chattarpur, The Mehrauli New Delhi-110074.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S NBT Banquet hall at Tivoli Garden, Khasra No. 646- 653,Village Chattarpur, The Mehrauli New Delhi-110074.

Sir,

This has reference to ID No. Online ID 2025120815515 dated 08/12/2025, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 05/01/2025 in the presence of Mr. Mukul, Manager and the following shortcomings were observed:-

1. 2 Exit of 1.8 meter width are provided against the requirements of 1.5m & 2.0 m width .
2. Exit & Lift signage's are not provided.
3. FCD found removed from lift lobby.
4. Terrace pump not in auto mode provision.
5. Further, kitchen has been extended up to corridor which is affecting the means of escape in case of any emergency, required to be unobstructed.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be issued at this stage. Further, the occupancy of the banquet hall premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully
20/1/26
A.K. Malik
Dy. Chief Fire Officer

**Copy to:**

1. 1. The DHO, Dy. Commissioner MCD Office ,South Zone , Green Park , New Delhi.