C-150

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 481 Dated: - 19/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s New Victoria Guest House, 1342, Sangtrashan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026042705820 dated 27/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 05/05/2026 in the presence of Md. Kamil, Manager and following shortcomings were observed: -

1. Hose reel found removed at 1st Floor.
2. Fire pump and Overhead Water Storage tank could not be checked as access to tank was not provided.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

19/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BP

Copy to: -

1. The Manager, M/s New Victoria Guest House, 1342, Sangtrashan, Paharganj, New Delhi - 110055.

Eating and Lodging Licensing Cell