C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 885 Dated:- 14/09/2026

To,

Sh. Ravi Pratap (Manager),
Nehru Academy, D-3/1 & D-3/2,
Vasistha Park, West Sagarpur,
New Delhi- 110046.

Subj.:- Regarding issuance of Fire Safety Certificate in respect Nehru Academy, D-3/1 & D-3/2, Vashisth Park, West Sagarpur, New Delhi- 110046.

Sir,

Please refer to your letter no. NA/2026/889 dated 08/06/2026, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 13/08/2026 in the presence of Sh. Karam (Owner). The inspection was carried out considering the school building as an old existing building on the basis of your aforesaid submission letter. Accordingly, the shortcomings earlier communicated vide letter no. F.6/DFS/MS/School/2019/SZ/6094 dated 14/10/2019 may be treated as null and void. During afresh inspection, it has been observed that the school building is comprised of Basement, Ground + 03 Upper Floors (basement not in use). However, the following shortcomings have been observed: -

1. First-Aid hose reel found Provided but not functional.
2. Terrace level pump having capacity 450 LPM found not provided.
3. Overhead tank of capacity 10,000 ltrs found not provided.
4. Exit signages found not provided.

In view of the above shortcomings, the application for issuance of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above-mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

10/9/26

A.K. Malik
Chief Fire Officer

10/09/26

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.