C-40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/GH/SZ/2026/ 495 Dated: / 21/05/ /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o M/s. New Daisy Home, located at M-1, First & Second Floor, Kalkaji, New Delhi-110019.

Sir,

Please refer to your online application no. No. 2026042405725 dated- 24/04/2026, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 07/05/2026 in the presence of Ms. Jamuna Negi (Manager) to see the functioning of fire safety equipment's provided in the building.

During inspection, Firesafety arrangements such as Fire Extinguishers, However, the following shortcomings were observed.

1. Fire-Aid Hose Reels are provided but not functional.
2. MOEFA is provided but not functional.
3. Main fire pump capacity of 450LPM is provided but not on auto mode.
4. Exit Signage are found removed.

In view of above shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

20/5/26

(A.K. Malik)
Chief Fire Officer

Copy to: -

1. The Owner/occupier, M/s. New Daisy Home, located at M-1, First & Second Floor, Kalkaji, New Delhi-110019. (Online application No. 2026042405725 dated- 24/04/2026).