C/49

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001**

No. F.6/DFS/MS/ Hospital/2025/SZ/ 622 Dated: 16/12/2025

To,

Mr. Ashok Kumar Pal
Dy. Director (Admin)
Vardhan Mahavir Medical Collage
& Safdarjung Hospital, New Delhi – 110029.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **New Emergency Block, Safdarjung Hospital, New Delhi – 110029**

Sir,

This has reference to File No. (E-35579/EST-17/12/2025-ESTATE dated 08/10/2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/10/2025 in the presence of Sh. R.S. Kushwaha, CSO, Sh. Yeshwant Singh, Maintenance and following shortcomings were observed:

1. Water curtain found nonfunctional.
2. Smoke management system in basement is found nonfunctional.
3. Automatic Sprinkler System found nonfunctional.
4. Discharge of main pump & Auto Starting/Manual stopping are not in auto mode.
5. Pressurization of Lift Shaft, Pressurization of lift lobby are nonfunctional and Lift Signage found removed.

In view of above, the case is hereby rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

16/12/25

(A. K. Malik)
Dy. Chief Fire Officer, SZ
Delhi Fire Service

Copy to: -

1. The Medical Superintendent, Ministry of Health & family welfare Vardhan Mahavir Medical Collage & Safdarjung Hospital, New Delhi – 110029.
2. The Estate Officer, SJH, Ministry of Health & family welfare Vardhan Mahavir Medical Collage & Safdarjung Hospital, New Delhi – 110029