C-101/75

आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/GH/NDZ/2026/275 Dated: -01/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Minto Road, Civic Centre,
New Delhi -110001.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s New Karan Guest House, 188-189-190 Ghee Mandi, Paharganj, New Delhi - 110055.

Sir,

This has reference to online application received through MCD online portal vide ID No. 2026030502356 dated 05/03/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on 13/03/2026 in presence of Mr. Shoaib (Manager) and observed that the shortcomings conveyed vide this office letter No. F6/DFS/MS/GH/NDZ/45 dated 24/01/2025 (copy enclosed) are not complied as yet.

In view of above, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. Further, the occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl.: As above

30/3/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service
OIC GH

Copy to:

1. The Proprietor, M/s New Karan Guest House, 188-189-190 Ghee Mandi, Paharganj, New Delhi - 110055.

c/90 C-100

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 45 Dated: 24./.01./2025

To,

The Manager
M/S New Karan Guest House,
188-189-190, Ghee Mandi,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o New Karan Guest House at 188-189-190, Ghee Mandi, Pahar Ganj, New Delhi

Sir,

This has reference to online id no. 2025010300081 dated 03/01/25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 20/01/25 in the presence of Mr. Deepak Thakar and following shortcomings were observed: -

1. Exhaust fan are not provided.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.
3. Exit Signage not provided.
4. Further, undertaking regarding not to use third floor for any purpose, as mezzanine counted as a floor, is also required to be submitted.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi