d4

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/SZ/2025/ 576 Dated:- 02/12/2025

To

Sh. Sudershan Kumar (Manager),
National Interner Exhange of India,
B-901, 9th floor, Tower B, WTC Nauroji Nagar,
New Delhi-110029.

Sub: Regarding No Objection Certificate in r/o M/s Office Space for NIXI at 9th floor, Tower B, World Trade Centre Nauroji Nagar, New Delhi.

Sir,

This has a reference to letter no. NIXI-002/11/2024-Admin dated 03/09/2025, on the subject cited above. In this regard, this is to inform you that the site was visited by the officer concerned of this department along with Ms. Rishu, NBCC on dated 06.11.2025, to check and verify the compliance of the condition of Fire Safety Certificate in r/o lay out of interior finishing /fit out of furniture and functionality /extension of existing firefighting arrangements. During the visit the following shortcomings were observed.

1. Hydrant coupling & nozzle from hose reel found missing at that floor.
2. Some detectors found nonfunctional.
3. Exit signages are also not provided at conspicuous location.

In view of above, the application for issuances of no objection certificate /FSC for occupy the space in said floor is rejected. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

24/11/25

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

o/c (2)

Copy to :

1. Sh. R.P. Singh, General Manager (Engg.), NBCC (india)Ltd.
2. Sh. Gaurav Meena, Addl. General Manager, NBCC (India) Ltd.