c/133

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS /MS/BP/2025/ School/791 Dated: 29 / 10 /2025

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
Dr. S.P.M Civic Centre, JLN Marg,
New Delhi -110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o addition/alteration of Nursery School Sector-16, Block-A, Rohini, Delhi.

Sir,

Please refer to your ID No. 10121190 dated 16.10.2025 on the subject cited above. In this connection, it is to inform you that the matter has been examined and the following shortcomings have been observed:

1. The width of the corridor is not proposed as per clause 7.11.2 (c) of UBBL-2016.
2. The position of staircases is not proposed as per clause 7.8.3 of UBBL-2016.
3. The dimension on the plans are not as per clause 2.0.4 (c) of UBBL-2016.
4. Fire and life safety arrangements as per Part IV of NBC 2016 are not proposed on the plans.
5. Proposed addition/alterations in the building are not shown in colour schemes as per clause 2.0.4(d) of UBBL-2016.

In view of the above, the building plans are rejected.

Yours faithfully,

(M.K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service
O/C 8/29/10