GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/ECN/2026/ 804 Dated: -25/08/2026

To,

The Chairman,
New Delhi Municipal Corporation,
Palika Kendra, Parliament Street,
New Delhi – 110001.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s P. K. Delicacies Pvt. Ltd., Ground Floor & First Floor of Residence Cum Office Complex, Yashwant Place, Chankyapuri, New Delhi-110021.

Sir,

Please refer your online application ID No. 2026072310026 dated 23/07/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on **12/08/2026** in the presence of **Sh. Vishnu, Manager** and following shortcomings were observed: -

1. Hose reel found removed at 1st floor.
2. MOEFA found removed at 1st floor.
3. P.A. system found removed.
4. Fire Check Doors found removed.

Keeping in view of the above **shortcomings**, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier

Yours Faithfully,

24/8/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C BR

Copy to: -

1. The Manager, M/s P. K. Delicacies Pvt. Ltd., Ground Floor & First Floor of Residence Cum Office Complex, Yashwant Place, Chankyapuri, New Delhi-110021.