d/49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/WZ/School/2026/ 423 Dated: -05/05/2026

To,

The Principal,
Panacea National Public School,
Libaspur Road, Siraspur, Delhi-110042.

Sub.:- Regarding issuance of Fire Safety Certificate in respect of Panacea National Public School, located at Libaspur Road, Siraspur, Delhi-110042.

Sir,

Please refer to your DFS online application no. 52026041302207 dated 13/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 23/04/2026 in the presence of Sh. Sunil Kumar (Caretaker) to check the compliance of shortcoming issued by this department vide letter no. F6/DFS/MS/2023/School/568 dated 07/12/2023 (copy enclosed).

During inspection, it has been observed that the shortcoming issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Enclosed: - As above

30/04/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal of Corporation of Delhi, Dr. S.P.M. Civic Centre, JL Nehru Marg, New Delhi-110002.
2. The Directorate of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

c/47 c/41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2023/School/ 568 Dated: 07 /12 /2023

To

The Principal
Panacea National Public School,
Libaspur Road Siraspur, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Panacea National Public School located at Libaspur Road Siraspur, Delhi-110042.

Sir,

Please refer to your letter no. PNPS/2023/DFS/059 dated 26.09.2023 received in this department vide outdoor dairy no.7231 dated 11.10.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.11.2023 to check the existing fire safety measures and observed that as per earlier Fire Safety Certificate issued by this department vide letter of even no.F6/DFS/MS/School/2013/WZ/1354 dated 27.12.2013 the building was comprised of ground & first floor only. Now the school management has been added one more floors the building composition is Ground & 02 upper floors only. At the time of inspection Sh. Lalit Kumar (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1 There is 2nos. of staircases provided with of 1.10m each against the requirement of 1.50m each.
2 Fire extinguisher provided but found not functional.
3 Hose reel hose not provided.
4 Terrace level fire fighting pump capacity of 450lpm not provided.
5 Terrace level fire water tank capacity of 10,000ltrs not provided.
6 Exit signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

9/12/23

(Atul Garg)
Director
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.