C/31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**
**NEW DELHI- 110001**

**No. F6/DFS/MS/Banquet/2025/SZ/** GN/492 **Dated:** 30/12/25

To,

The Owner/Occupier,
M/s Parisian Banquet,
Prop. No. 84 & 85, Block- B, Pocket- 10,
Sector- 13, Dwarka, New Delhi- 110078.

**Sub:** -Regarding issuance of "FSC" in respect of M/s Parisian Banquet a Unit of Parisian Hotels Private Limited at Prop. No. 84 & 85, Block- B, Pocket- 10, Sector- 13, Dwarka, New Delhi- 78.

Sir,

Please refer to online application ID 2025112115041 dated 26.11.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the banquet hall building on dated 18.12.2024 in the presence of Manager to verify the fire safety arrangements in accordance with the rules, having area 392 $m^2$ at each floor.
At the time of inspection, it was observed that the banquet hall running at ground & upper ground floor only in a building comprised of basement (other's property), ground, upper ground plus two upper floors, and following shortcomings were observed: -

1. Two staircases with width of 1.50 meter each found provided against requirement of two staircases with width of 2.0 meter each.

In view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running banquet hall in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

30/12/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone