GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/GH/2026/NZ/832 Dated: 09/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg
New Delhi 110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s. Town House Guest House located at House No. 38, Kailash Enclave, Pitampura, Delhi-110034.

Sir,

This has reference to online application received through MCD portal vide ID- 2026081610497 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 22/08/2026 to see the compliance of requisite fire safety measures. Sh. Shyam was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire check door found removed at some places.
2. Carbon Monoxide detectors found provided but not functional.
3. Inspection ladder found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

9/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. M/s Tent House Guest House located at House No. 38, Kailash Enclave, Pitampura, Delhi-110034.
2. MCD Portal ID No. 2026081610497.