GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/ 581 Dated: 22/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Play located at Shop No. TF 01, City Square Mall, Plot no. 7 & 8, Shivaji Place, District Centre, Raja Garden, Delhi-110027.

Sir,

This has a reference to MCD application No. 2026051606991 dated 16/05/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 06/06/2026 in the presence of Mr. Praveen Kumar to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. FCD found removed in kitchen.
2. Sprinkler at some places found hidden inside false ceiling and some cubical found constructed without sprinkler heads.
3. Exits signage were found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dr. S.K Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, M/s Play located at Shop No. TF 01, City Square Mall, Plot no. 7 & 8, Shivaji Place, District Centre, Raja Garden, Delhi-110027.