GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2025/ 554 Dated: 26/11/2025

To,

The Authority Signatory,
Plot No. 52, Ohkla Industrial Area,
Phase – I, New Delhi – 110020.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Plot No. 52, Ohkla Industrial Area, Phase – I, New Delhi – 110020.

Sir,

This has a reference to your Outdoor Dairy No. 6362 dated 24/09/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03/11/2025 in the presence of Mr. Anil Kumar Lamba and observed that building comprised of Basement, Ground plus two upper floors and following shortcomings were observed during time of inspection:

1. Hose reel hose provided but nonfunctional.
2. Automatic Sprinkler concealed with false ceiling at ground floor.
3. Fire pump of 900 LPM provided but nonfunctional.
4. Exit Signage's and lift signage's found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi - 110024.