**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/Industrial/SZ/2026/307 Dated: 22/07/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o M/s Plot No.12, Block-F, Okhla Industrial Area, Phase-I, New Delhi-110020.

Sir,

Please refer to your online application no. No. 10120620 dated-29/06/2026, on the subject cited above. In this connection, it is to inform you that the premises was jointly inspected by officers concerned of this department on 02/07/2026 in the presence of Sh. Chetan Singhal JE (Bldg.) MCD & Sh. P.K Chauhan AE(Bldg.) MCD

During inspection, the following shortcoming was observed.

1. Pressurization of the staircases serving to basement is not provided.

In view of above shortcomings, the application for issuance of Fire safety Certificate is cannot consider at this stage. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

22/7/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier M/s Plot No.12, Block-F, Okhla Industrial Area, Phase-I, New Delhi-110020. (Online application No. 10120620 dated-29/06/2026).