GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS /MS/BP/2026/ 401 Dated: 10/09/2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Subject: Examination of building plans from fire safety point of view in r/o Plot No-6, Block No G-1, situated at G.T. Karnal road Industrial Area, Delhi.

Sir,

With reference to the online request ID No. 20031821 dated 25.08.2026 on the subject cited above. In this connection, it is informed that the matter has been examined and the following shortcomings have been observed:

1. The stilt floor is not open on the rear side as required in Clause 1.4.111 of UBBL-2016.

In view of the above-mentioned shortcomings and non-compliance with the provisions of UBBL-2016 and NBC-2016, Part-IV, the building plans, as submitted, cannot be considered from the fire and life safety point of view and are hereby **rejected**.

Yours faithfully,

9/9/26

(A. K. Malik)
Chief Fire Officer
Delhi Fire Service