GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/2026/WZ/ 369 Dated: - 13/08/2026

To,

The Authorized Signatory,
Community Centre, Plot No. 7,
Anushka Tower-, Garg Trade Centre,
Sector-11, Rohini, Delhi-110085.

Subj.:- Corrigendum regarding addition of shortcoming in the Shortcoming Letter issued in respect of Community Centre, Plot No. 7, Anushka Tower-2, Garg Trade Centre, Sector-11, Rohini, Delhi-110085.

Sir,

With reference to the DFS Online Portal Application ID. No. 52026070204186 dated 24/07/2026 on the subject cited above. In this connection, it is to inform you that the premises, namely Community Centre, Plot No. 7, Anushka Tower-2, Garg Trade Centre, Sector-11, Rohini, Delhi-110085, was inspected by the officer concerned of this department from the fire safety point of view.

It has been noticed that the following shortcoming, which was observed during the inspection, was inadvertently not reflected in the online-generated shortcoming letter: -

1. **Staircases**: - *"The required width of the two staircases is 1.50 metres and 2.00 metres, respectively, whereas the width of both the staircases provided at site is 1.50 metres each. Therefore, the staircase provision does not comply with the required fire and life safety provisions".*

Accordingly, the above-mentioned shortcoming shall be treated as an integral part of the shortcomings communicated vide the shortcoming letter issued against applicant id no. 52026070204186 dated 24/07/2026. The applicant is advised to rectify the above-mentioned shortcoming and thereafter apply afresh for further necessary action by this department.
All other contents of the original shortcoming letter shall remain unchanged.

Yours faithfully,

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service