GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/BP/2026/ 284 Dated: 09/07/2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th floor, Minto Road, New Delhi

Sub: Clearance of plans from fire safety point of view in r/o Plot No. 84/6, Block No. 2, Kirti Nagar, W.H.S., New Delhi-110015.

Sir,

Please refer to your online ID No. 20030053 dated 30.06.2026 on the subject cited above. In this connection, it is submitted that the building plans were scrutinized from fire safety point of view and following shortcomings are observed.

1. Stilt floor is not proposed as per clause 1.4.111 of UBBL-2016.
2. Staircases are not discharging as per clause 7.11 (l) of UBBL-2016.

Accordingly, the building plans are rejected.

Yours faithfully

A.K. Malik
Chief Fire Officer (HQ)
Delhi Fire Service