C/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/Industrial/SZ/2025/ 535 Dated: 12/11/2025

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002

Sub: - Regarding renewal of Fire Safety Certificate in r/o Building located at Plot no. 95, FIE, Patparganj Industrial Area, Delhi-92.

Sir,

With reference to the letter bearing outdoor diary no. 6553 dated 29.09.2025 on the subject cited above, it is informed that the said building was visited by officer concerned from this department on 31.10.2025 in the presence of Mr. Vipin Jain and it was following shortcomings were observed:

1. Outdated Fire Extinguishers to be replaced.
2. Hose reel at Ground & 1st floor found removed and available Hose reel in basement found non functional.
3. Electrical panel and inverter system in staircases to be removed.
4. Terrace fire pump found non functional.
5. Electrical wires in Hose reel cabinet must be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

13/11/25

(Dr. S.K. Tomar)
Dy. Chief Fire Officer (NDZ)
Delhi Fire Service

Copy to –

1. The Owner/Occupier/Manager, Plot no. 95, FIE, Patparganj Industrial Area, Delhi-92.