GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

No. F.6/DFS/MS/School/SZ/2026/ 795 Dated: 24/08/2026

To,

The Principal,
P.M Modern Public School,
L-1-77 B/10, Sangam Vihar,
New Delhi-110080.

Sub: Regarding issuance of Fire Safety Certificate in r/o. P.M Modern Public School located at L-1-77 B/10, Sangam Vihar, New Delhi-110080.

Sir,

This is reference to your letter no nil dated- 19/05/2026 received through outer diary no-1470 dated-22/05/2026 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department 03/08/2026 in the presence of Sh. Vijay Singh.

During the inspection it has been observed that earlier the school building comprised of Ground Floor plus One Upper Floor and was not accessible through a 6.0-meter-wide road. Subsequently, the owner/occupier purchased the adjoining property abutting a 6.0-meter-wide road and integrated the same with the existing school premises. Now the school building comprised of Ground Floor plus Three Upper Floors and has direct access from the 6.0-meter-wide road. However, the following shortcomings were observed.

1. Width of staircases 1X1.8, 1X1.0m &1X0.75m are provided against the requirement of 2X1.5m.
2. 450 LPM pump provided at terrace level but not on auto-mode.
3. Exit signages are not provided.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage.

Yours faithfully,

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Director, Directorate of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.