GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/730 Dated: 15/09/2025

To

The Principal,
PM Shri Kendriya Vidyalaya,
Masjid Moth, Sector–03,
Sadiq Nagar, New Delhi–110049

Sub: Renewal of Fire Safety Certificate in r/o PM Shri Kendriya Vidyalaya, Masjid Moth, Sector–03, Sadiq Nagar, New Delhi–110049

Sir,

This is with reference to your letter No. F.1-20/KV/MM/2025-26/109 dated 17/07/2025, received in this department vide outdoor diary No. 4364 dated 31/08/2025 on the subject above. In this connection, it is to inform you that the premise was inspected by the concerned officer of this department on 01/09/2025 in the presence of Ms. Asfia (Incharge). During course of inspection, the shortcomings observed are as below.

1. First-aid hose-reel provided found non-functional.
2. Terrace level fire pump found non-functional.
3. Overhead water tank exclusive for fire-fighting found empty.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action.

Yours faithfully,

12/9/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Assistant Commissioner, KVS Delhi Region, JNU Campus, New Mehrauli Road, New Delhi–110067