GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 298 Dated: - 28/07/2026

To,

The Station House Officer,
Police Station, Special Cell & Staff Quarters,
Sector-22, Rohini, New Delhi-110085..

Sub.: - Regarding renewal of Fire Safety Certificate in respect Police Station, Special Cell & Staff Quarters, located at Sector-22, Rohini, New Delhi-110085.

Sir,

This has reference to the letter no. 12063/Admin.(1)/Rohini District dated 05/05/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 29/06/2026 in the presence of Sh. Vijay Samaria (SHO). During inspection, it was observed that the said buildings are comprised of Police Station (Business Building) – B+G+03 and Residential Building – G+07. After the inspection, the following shortcomings were observed: -

1. Smoke Management System found removed.
2. First-Aid Hose Reels found non-functional.
3. Automatic Sprinkler System found non-functional.
4. Fire pumps found non-functional.
5. Communication in lift car, Fireman's Grounding Switch and Lift Signage found non-functional.

In view of the above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

28/07/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Commissioner of Police, Rohini District, Delhi.