C105

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/NZ/BNQT/2026/759 Dated: 06/08/2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **M/s Prakash Continental located at Prop. No. 13, Wazirpur Printing Press Area, Behind Punjab Kesari Press, Near Wazirpur Press, Near wazirpur Bus Depot, Delhi - 110035.**

Sir,

This has reference to MCD online application ID No. 2026071609857 dated 16.07.2026 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.07.2026 in presence of Mr. Mohan Prakash Gupta (Owner) and it was observed that the building is comprised of Basement + ground + 02 upper floor. During inspection shortcomings were observed:

1. The alternate staircase are non-accessible from upper floors due to material staking.
2. Smoke detector system is provided but non functional.
3. Manually operated electric fire alarm is provided but non functional.
4. Terrace fire pumps were not found in auto start mode.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

5/8/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/L 05/8

Copy to:-

The Licensee,
M/s Prakash Continental located at Prop. No. 13, Wazirpur Printing Press Area, Behind Punjab Kesari Press, Near Wazirpur Press, Near wazirpur Bus Depot, Delhi - 110035.