आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2026/NZ/765 Dated: 07/08/2026

To

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre, Minto Road,
New Delhi–110002
Email ID commissioner@mcd.nic.in

Sub: Regarding issuance of FSC in r/o M/s Prakash Continental located at Plot No 13, FF & SF, Gazipur Printing Press Area Behind Punjab Keshari Press Wazirpur Bus Depot Delhi

Sir,

This has reference with **MCD Portal ID 2026071609863 Dated 17/07/2026** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 31/07/2026 in the presence of Mr. Mohan Parkash Gupta to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. Fire check door not provided.
2. Smoke ventilation system not provided in the building as per clause 7.31 of UBBL 2016.
3. First aid hose reel not provided at 2nd floor.
4. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
5. MOEFA provided but not working.
6. Automatic Sprinkler system provided but not working.
7. Terrace level pumps capacity 900 LPM not working.
8. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

7/8/26

(Dr. S.K Tomar)
Chief Fire Officer
Delhi Fire Service