GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

C64

No. F.6/DFS/MS/Bnqt/2026/SZ/332 Dated: 16/04/2026

To

The Commissioner,
Municipal Cooperation of Delhi,
9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi–110002

Sub: **Regarding renewal of Fire Safety Certificate in r/o M/s Precious Moments Banquet (A unit of Precious Banquets Pvt. Ltd) at B-1/627, Janak Puri, New Delhi–110058**

Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. **2026032303404** dated 23/03/2026. In this connection, it is to inform you that the said banquet was inspected by the officer concerned of this department on 01/04/2026 to verify the compliance of fire safety provisions required under the rules in the presence of Mr. Satish Kalyanpur (Supervisor). During course of inspection, the shortcomings observed are as below.

1. The smoke management system found removed.
2. First-aid hose-reel system provided found non-functional and nozzle missing.
3. Internal hydrants found non-functional & hose-box empty.
4. Fire pumps (Ground & terrace level) found non-functional.
5. Lift signage found removed.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the premise in the absence of requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier/management in the interest of public safety.

Yours faithfully,

16/4/26

(A.K. Malik)
Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

01887

1. Authorized Signatory, M/s Precious Moments Banquet (A unit of Precious Banquets Pvt. Ltd) at B-1/627, Janak Puri, New Delhi–110058.