GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/CGHS/SZ/2025/ 573 **DATED:** 01/12/2025

To,

The President,
Prerna CGHS Ltd.
Plot No – 13, Sector – 10, Dwarka,
New Delhi – 110075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Prerna CGHS Ltd. Located at Plot No – 13, Sector – 10, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter No. PGHS/25-26/Fire/2024 dated 14/05/2025 on the subject cited above. In this connection it is to inform you that the above said premises was re-inspected by the officer concerned of this department on 15/11/2025 in the presence of Sh. Akshay (Caretaker) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. The internal road around the building found encroached/blocked.
2. Nozzle of First Aid Hose Reels are found missing at some places.
3. Exit signage's found removed at some places.
4. Trimming of the trees must be done to provide clear passage around the building to fire vehicles in case of any emergency.

You are requested to comply the above mentioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.