C/776

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 417 Dated: -05/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Prince Palace Dx., 5115, Gali Thanedar Wali, Main Bazar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026041304939 dated 13/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 22/04/2026 in the presence of Sh. Mukesh, Manager and following shortcomings were observed: -

1. Automatic operation of Fire Pump found removed.
2. Domestic connection in overhead water storage tank is not permitted.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

4/05/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C BR

Copy to: -

1. The Manager, M/s Prince Palace Dx., 5115, Gali Thanedar Wali, Main Bazar, Paharganj, New Delhi - 110055.