C150

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/Bnqt/2025/WZ/ 165 Dated: 30/09/2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, JLN Marg,
Minto Road, New Delhi–110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o "Pristine Palace Boutique Banquet" at 16–A, Main Najafgarh Road, Moti Nagar, Delhi–110015

Sir,

Please refer to the online portal application No. **2025091013327** dated 10/09/2025. In this connection, it is to inform you that the said premise was re-inspected by the officer concerned of this department on 18/09/2025 in presence of Sh. Eash Arora (Liaison Officer) to verify the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/Banq./2025/WZ/82 dated 15/05/2025 and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Observation
1.	Smoke management system not provided in banquet hall.	Not complied.
2.	First-aid hose-reel nozzle found missing at some places.	Not complied.
3.	Detectors found non-functional at some places.	Not complied.
4.	P.A. System is not provided.	Not complied.
5.	Internal hydrant found provided but non-functional.	Complied
6.	Pump room found locked, hence, pumping arrangements could not be checked.	Not complied
7.	Terrace level pump not found in auto mode.	Not complied
8.	Overhead water tank of 10,000 liters capacity provided against required capacity of 20,000 liters.	Not complied (Work in progress)
9.	Exit signage's not provided.	Not complied

In view of the above, application for issuance of fire safety certificate cannot be considered & rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

29/9/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Nodal Officer/DFS ..... with the request to upload on online MCD Portal.