GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/College/ 1905 Dated: 29/10/2025

To

Sh. Anil Kapoor (Partner),
M/s Kapoor Sons & Co.,
Ground Floor, 112-113,
Gautam Nagar, New Delhi.

Sub: Renewal of Fire Safety Certificate in r/o Building at Property No. 112-113, Gautam Nagar, New Delhi-110029.

Sir,

This has a reference to your letter No. Nil dated 01/09/2025 received through outdoor diary No. 5520 dated 02/09/2025, on the subject cited above. In this connection, it is to inform you that the premise was re-inspected by the officer concerned of this department on 16/10/2025 in the presence of Abhishek Kapoor, Owner & Manish Kumar to verify the compliance of the shortcomings issued vide letter No. F6/DFS/MS/SZ/2025/439 dated 03/09/2025 and observed that the shortcomings are not fully complied.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(A. K. Malik)
Dy. Chief Fire Officer, SZ
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, 8th Floor, Dr. S.P.M. Civic Centre, JLN Marg, New Delhi-02.
2. The Dy. Commissioner, MCD, South Zone Aurobindo Marg, Green Park, New Delhi-110016.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

C/199
C/205

No. F.6/DFS/MS/2025/SZ/ 439 Dated: 03/09/2025

To

Sh. Anil Kapoor (Partner),
M/s Kapoor Sons & Co.,
Ground Floor, 112-113,
Gautam Nagar, New Delhi–110049

Sub: Renewal of Fire Safety Certificate in r/o Building located at Property No. 112–113, Gautam Nagar, New Delhi–110029.

Sir,

This is with reference to your letter No. Nil dated 11/07/2025 received in this department vide outdoor diary No. 3682 dated 11/07/2025 regarding compliance of shortcomings earlier communicated vide letter No. F.6/DFS/MS/2025/SZ/285 dated 16/06/2025. In this connection, it is to inform you that the said premises was re-inspected by the concerned officers of this department on 05/08/2025 in the presence of Mr. Amit Rajput to verify the compliance of shortcomings earlier communicated vide above referred letter. During course of inspection, the shortcomings observed is as below.

1. 6-meter-wide road around the building found encroached/blocked.
2. Hose-reel, hydrant & sprinklers found partially functional.
3. Basement is used for grocery outlet (sale & storage) & coaching center with blocked/ insufficient entry/exit/escape in the event of an incident.
4. Standby diesel pump found non-functional.
5. Inadequate fresh air in pump house.
6. Coaching Centre of DAMS FMGE running at 2nd floor.
7. Restaurant still running at stilt floor.

In view of the above shortcomings, renewal of fire safety certificate cannot be considered at this stage & rejected. You are directed to rectify the above-mentioned shortcomings without further delay, otherwise; suitable necessary action under Delhi Fire Service Act & Rules, 2010 shall be initiated including disconnection of electricity and water supply.

Yours faithfully,

9/9/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Commissioner, Municipal Corporation of Delhi, South Zone, Aurobindo Marg, Green Park, New Delhi–110016 .....with the request to take necessary action.