GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/140 Dated: 23/04/2026

To,

The General Manager,
M/s Punjabi Bagh Club,
Punjabi Bagh, Ring Road,
Delhi – 110026.

Subject: - Joint Inspection of M/s Punjabi Bagh Club Under the Jurisdiction of District (West).

Sir,

With reference to the Letter No. F. No. 55/DDMA(W)/S. A /2014/2137 dated 28.03.2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department along with representative of other agencies, in the presence of Mr. M. Wadhwa (General Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. Fire alarm system not working at some location.
2. Exit/Escape route blocked at some places.
3. Exit signage not provided at some locations.
4. Terrace pump not on auto mode.
5. Door handle of some exit door found broken.
6. Hose reel found leaked at some location.
7. Smoke ventilation system found provided but not functional.
8. Temporary structure under staircase.

In view of above shortcomings, the Fire Safety Certificate issued by this department vide letter no. F6/DFS/MS/WZ/2025/265 dated 21/05/2025 stands **Cancelled.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The SDM (DDMA), District West, Plot No.-3, Shivaji Place, Raja Garden, New Delhi-110027: for information please.
3. The Dy. Health Officer, MCD, Vishal Enclave, Rajouri Garden, New Delhi-110027.