C-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2026/SZ/ 169 Dated: 24/02/2026

To,

The Owner/Occupier,
M/s Punter House Cafe Reloaded (A unit of Crossroad Hospitality Pvt. Ltd.),
Shop No. 102-106, 1st floor, City Centre Mall, Plot No 5
Sector- 12, Dwarka, New Delhi- 110075.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Punter House Cafe Reloaded (A unit of Crossroad Hospitality Pvt. Ltd.), at Shop No. 102-106, 1st floor, City Centre Mall, Plot No. 5, Sector- 12, Dwarka, New Delhi- 110075.

Sir,

This has a reference to MCD online application ID No. 2026012200785 dated 29.01.2026, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on dated 16.02.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Abhinav Sharma (Manager) was present and it was observed that the aforesaid eating running at ground floor only, and following shortcomings were observed: -

1. 2nd exit found blocked with sitting arrangements.
2. MOEFA found provided but not functional.
3. Exit Sign's found removed.

Keeping in view of the above, renewal of fire safety certificate can-not be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department, and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(M.K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Joint C.P. (Lic.), 1st floor, P.S. Defence Colony, New Delhi- 110024.
2. Online application ID No. 2026012200785 dated 29.01.2026.