**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/Apartment/SZ/2026/292 Dated: 15/07/2026

To

The Executive Engineer (E),
PWD Elect. Divn. South (M),
Sukhdev Vihar, Mathura Road,
New Okhla Flyover, New Delhi-25.

Ref:- Letter bearing outdoor diary no. 1270 dated 15/05/2026

Sub: - Regarding renewal of Fire Safety Certificate in r/o Quarters of General Pool of Govt. of India (Tower A, B & C) located at Sec "D", Pocket – II, Vasant Kunj, New Delhi.

Sir,

In context to the letter mentioned in reference, it is informed that the said building was visited by officer concerned of this department on 23/06/2026 in the presence of Mr. Sh. Krishna Nand Kumar Jaiswal, A.E.(PWD) and following shortcomings were observed during the inspection.

1. Manual Operated Electrical Fire Alarm (MOEFA) found not provided.
2. Terrace fire pump found non functional in C block.
3. The electrical wire/cables in FHC must be removed.

In view of above shortcomings, the application of renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

((A K Malik)
Chief Fire Officer
Delhi Fire Service

Copy to:-.

1. The Superintending Engineer PWD South Circle, Sukhdev Vihar, Near Okhla Flyover, New Delhi.
2. The Secretary RWA D-II Flat, Vasant Kunj, New Delhi.
3. The Assistant Engineer-II PWD Hauz Khas, New Delhi.