GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 864 Dated:- 10/09/2026

To,

The Principal,
Radiant Model School, 269,
Jail Road, Nangal Raya,
New Delhi- 110046.

Subj.: - Regarding inspection of Radiant Model School, 269, Jail Road, Nangal Raya, New Delhi-110046 to issue N.O.C for Fire Safety Certificate.

Sir,

Please refer to your letter no. nil dated 22/06/2026 received through outdoor diary no.2738 on the subject cited above. In this connection it is to inform you that officer concerned of this department inspected the building on dated 20/07/2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Raghvender Singh (Manager) was present and it was observed that the building is comprised of ground plus three upper floors and have following shortcomings: -

1. An additional staircase shall be provided 1.5 wide.
2. First aid hose reel not provided.
3. Fire Pump having 450 LPM output 40 M head not provided at terrace.
4. Overhead water tank 10, 000 liters not provided.
5. Exits signage's are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

A.K. Malik
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.