c/60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DLEHI - 110 001

No. F.6/DFS/MS/WZ/EH/2026/ 390

Dated: 27/04/2026

To,

Mr. Vasu Aggarwal,
House No.86, Kapli Vihar, Near Kohat Enclave,
Delhi-110034.

Sub: Renewal of FSC in r/o M/s Rajbhog Food India, Property No.E 2/256, Old Plot No.255, 255-A, 256 & 256-B, GF, Shastri Nagar, Delhi-110052.

Sir,

This is refer to online application no. 2026032903803 dated 04.04.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 17.04.2026, in presence of Mr. Mukesh Bansal to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. The width of the alternate exit door was found reduced to 0.90 m and the same was observed to be permanently closed.
2. Fire extinguishers were found empty at the time of inspection.
3. Manually operated electric fire alarm is provided but not functional.
4. The terrace fire pump was found neither operational nor in auto mode.
5. The capacity of the terrace water tank was found reduced to 5000 litres

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

27/04/26

(S.K.Dua)
Chief Fire Officer
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026032903803 dated 04.04.2026.